



# HLXS.EX6662 - Butterfly Valves

## Butterfly Valves

See General Information for Butterfly Valves

### LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

EX6662

UNIT 8, CALIBRE INDUSTRIAL PARK

LACHES CLOSE FOUR ASHES

WOLVERHAMPTON, WV10 7DZ UNITED KINGDOM

Model 2305-300-LF butterfly valves, sizes 2, 2.5, 3, 4, 5, 6, 8, 10 and 12 in. with wafer type end connection for aboveground installations having a rated pressure of 300 psig. The Model 2305 butterfly valves can be factory fitted with supervisory tamper switches for indoor/outdoor use.

Model 2905-300-LF butterfly valves, sizes 2, 2.5, 3, 4, 5, 6, 8, 10 and 12 in. with grooved type end connections for aboveground installations having a rated pressure of 300 psig. The Model 2905 butterfly valves can be factory fitted with supervisory tamper switches for indoor/outdoor use.

Models 2305-250-LF, 2305-200-LF butterfly valves, sizes 2, 2.5, 3, 4, 5, 6, 8, 10 and 12 in. with wafer type end connection for aboveground installations having a rated pressure of 300, 250, 200 psig. The Model 2305 butterfly valves can be factory fitted with supervisory tamper switches for indoor/outdoor use.

Models 2905-250-LF, 2905-200-LF butterfly valves, sizes 2, 2.5, 3, 4, 5, 6, 8, 10 and 12 in. with grooved type end connections for aboveground installations having a rated pressure of 300, 250, 200 psig. The Model 2905 butterfly valves can be factory fitted with supervisory tamper switches for indoor/outdoor use.

Model BFV-G, sizes 2-1/2, 3, 4, 6 and 8 in.; DN65, DN80, DN100, DN150, DN200, groove end type.

Model BFV-W, sizes 2-1/2, 3, 4, 6 and 8 in.; DN65, DN80, DN100, DN150, DN200, wafer type.

The BFV-G, BFV-W valves are rated for pressures not exceeding 175 psig.

The BFV-G and BFV-W valves may be provided with factory installed supervisory tamper switches for indoor use only.

Last Updated on 2015-09-08

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions:

1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings).
2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"