

USQT.S35796 - Extinguishing System Attachments

Extinguishing System Attachments

See General Information for Extinguishing System Attachments

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

UNIT 8, CALIBRE INDUSTRIAL PARK
LACHES CLOSE FOUR ASHES
WOLVERHAMPTON, WV10 7DZ UNITED KINGDOM

S35796

SPRINKLER SYSTEM ALARM INITIATING DEVICES


Wet Pipe, Paddle Type

Model	Size In.	Pipe Schedule	Max System Pressure psig
LF-JZL-50	2	10 thru 40	450
LF-JZL-65	2.5	10 thru 40	450
LF-JZL-80	3	10 thru 40	450
LF-JZL-100	4	10 thru 40	450
LF-JZL-125	5	10 thru 40	450
LF-JZL-150	6	10 thru 40	450
LF-JZL-200	8	10 thru 40	450

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

Model	Oper Pressure psig	Max System Pressure psig
LF-SSOSY-1	N/A	N/A
LF-SSOSY-2	N/A	N/A
LF-SSOSY-3	N/A	N/A
LF-SIP-1	N/A	N/A
LF-SIP-2	N/A	N/A
LF-SIP-3	N/A	N/A

Marking: Trademark and/or Tradename  , "LIFECO"

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"