



# VPLX.EX6005 - Valves, Alarm

## Valves, Alarm

See General Information for Valves, Alarm

### LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

EX6005

UNIT 8, CALIBRE INDUSTRIAL PARK

LACHES CLOSE FOUR ASHES

WOLVERHAMPTON, WV10 7DZ UNITED KINGDOM

Model A, 4 and 6 in. size alarm valves with flanged ends used with Model A retarding chamber and Model A water motor gong in vertical position.

Models A, 3, 4, 6, 8 in. size for vertical installation only may be providing with constant pressure trim or variable pressure trim for use with Model RA rated chamber; Model GA water motor and gong.

Model LF-WAV100BF, 4 in. size with flange-flange end configuration for rated pressures not exceeding 175 psig. For vertical installation.

Model LF-WAV150BF, 6 in. size with flange-flange end configuration for rated pressures not exceeding 175 psig. For vertical installation.

Model LF-WAV100PF, 4 in size with flange-flange end configuration for rated pressures not exceeding 200 psig. For vertical installation.

Model LF-WAV150PF, 6 in. size with flange-flange end configuration for rated pressures not exceeding 200 psig. For vertical installation.

Model LF-WAV100BG, 4 in size with groove-groove end configuration for rated pressures not exceeding 200 psig. For vertical installation.

Model LF-WAV150BG, 6 in. size with groove-groove end configuration for rated pressures not exceeding 200 psig. For vertical installation.

Model LF-WAV200A, 8 in. size with flange-flange and groove-groove end configurations for rated pressures not exceeding 250 psig. For vertical installation.

**Alarm valves**, Models BSAV, BSWM, BSRC.

Last Updated on 2017-03-31

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"